

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3295-0250:005 Page 1 of 1

CATEGORY: Fire-Rated Door

LISTEE: Haley Brothers, 6291 Orangethorpe Ave., Buena Park, CA 90620
Contact: Wayne Freeze (714) 670-2112

DESIGN: Wood particleboard core with face materials (with or without wired glass vision panels).
Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: CSFM label.

APPROVAL: Listed as a 1/3-hour fire-rated wood passage door when installed in a frame approved for the type of wall construction.

NOTE: Formerly 3300-0250:005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager